



IMPORTANT: Confirm the riser feed and sleeve through the slab are correctly placed before the slab is poured so the minimum clearances are met.

The riser room shall be used for fire protection equipment and controls only. The minimum size of the room shall allow adequate firefighter access with the following clearance requirements:

- The riser assembly shall have a minimum of 36 inches of clear working space around the pipe. If placed along a wall or in a corner, the riser shall be a minimum of 18 inches away from the wall.
- There shall be a minimum of 36 inches of clearance in front of the FACP.
- If a roof access ladder is located in the fire riser room, there shall be 36 inches of clearance in front of the ladder and 24 inches on each side of the ladder.